

Office of the Director Fire & Emergency Services, J&K  
Jammu/Srinagar

The Principal  
RMG International School  
Village Jandial, Zone Bhalwal  
District Jammu

No: DFES-FP/9/2022-04(CC-7079422) - 257

Dated: 26-12-2022

Sub: Provisional Fire Safety Certificate.

Ref: Your online application submission dated: 01.12.2022 (FI-068429).

The inspection of above said school was got carried out by the inspecting officer of this department. During inspection it was found that the management has installed one Hose Reel Hose (covered only ground floor of the building), Smoke Detectors, Fire Alarm and First Aid Fire Extinguishers in their school premises. The school is about 08 Km away from Fire and Emergency Services Station Akhnoor. Since the school is already functioning, as such, the management can proceed ahead for operation provisionally subject to adopt the following fire safety precautionary measures in letter and spirit forthwith:-

1. 01 No. of CO<sub>2</sub> Type fire extinguisher of 4.5 Kg capacity should be provided near main electric switch board panel in addition to already existing fire extinguishers.
2. All exits/entrances should be kept open and free from any obstruction for easy and safe evacuation of inmates during any emergency.
3. During inspection, it was found that the Hose Reel Hose installed at ground floor can't cover all floors of the school building. As such, it is strongly recommended that Hose Reel Hose should be upgraded and installed in such a way where from every nook and corner of the school building are covered easily at the time of any emergency.
4. First Aid Fire fighting system installed in the school building should be checked periodically. Staff and students should be fully trained in handling / operating of fire fighting system installed in the school building. The management shall intimate this office in writing after each quarter that the fire fighting equipments installed in the school are functioning.
5. All class rooms and examination halls having seating capacity for more than 45 students need to be provided with two exits.
6. All electric installations existing in the building should be concealed conduit type.
7. The corridor of the building shall not be used for any kind of storage.
8. No Hazardous material should be kept inside of the school premises (especially LPG cylinder, Petrol and Diesel etc.). Any deviation found in this regard, this provisional clearance will be treated automatically withdrawn/cancelled.
9. The management of the school shall be wholly and solely responsible for keeping the fire fighting system in working condition 24x7 and safe evacuation of its students during any mishap.
10. At present school is triple storey. As such no addition / alteration should be made by the school management in the existing structure without prior permission from this department. Any deviation found in this regard, this provisional clearance will be treated automatically withdrawn/cancelled.
11. The department can make a surprise visit to your school at any time. During the visit if the fire fighting system (i.e. existing as well as proposed) found defunct and deviation, this provisional clearance issued shall be treated automatically withdrawn/cancelled.
12. This provisional clearance shall be subject to outcome of any dispute/investigation/enquiry/trial if any, pending before any Court of Law/investigation agency. This provisional clearance shall not confirm any title upon the person/company in whose favour it is issued.
13. The validity of this provisional clearance shall remain in force for one year and same needs to be renewed after checking of fire fighting system installed in the school building (i.e. existing as well as proposed). However, before granting permission/recognition/ extension or renewal thereof, the competent authority shall satisfy himself in terms of conditions laid down in SRO-123 of 2010, issued by Education Department with regard to physical facilities.

Director

Fire & Emergency Services, J&K  
Jammu/Srinagar

Chairman

RMG International School  
Jandial ( Zone Bhalwal ), Jammu

Principal

RMG International School  
Jandial ( Zone Bhalwal ), Jammu