

S.D. Water Testing Laboratory, Akhnoor

Jal Shakti Division, Near PDD Office, Akhnoor. Pin- 181201



PAYMENT RECEIPT

Sample id: U1700970S15146007

Candidate name: RMG INTERNATIONAL SCHOOL

Contact number: 9419100339

Sample Received Time: 2023/09/09 13:30

Expected Report Delivery Date: 2023/09/11 12:31

Amount

Sr. No.	Test name	Amount
1	Turbidity	₹ 5.00
2	pH	₹ 1.00
3	TDS	₹ 1.00
4	Total Alkalinity (as Calcium Carbonate)	₹ 20.00
5	Chloride (as Cl)	₹ 50.00
6	Fluoride (as F)	₹ 50.00
7	Nitrate (as NO ₃)	₹ 50.00
8	Sulphate (as SO ₄)	₹ 50.00
9	Calcium (as Ca)	₹ 50.00
10	Total Hardness (As CaCO ₃)	₹ 20.00
11	Iron (As Fe)	₹ 50.00
12	E. coli	₹ 100.00
13	Free residual Chlorine	₹ 1.00

M. S. Rathore
Principal
RMG International School
Jandial (Zone Bhalwal), Jammu

Total = ₹ 448.00

Note: This is an auto generated receipt no signature required

Designed & developed by NIC . Copyright © NJJM 2020

M. V. Rathore

Principal
RMG International School
Jandial (Zone Bhatwal), Jammu

Jal Jeevan Mission

Har, Oter Jal



S.D. Water Testing Laboratory, Akhnora

Jal Shakti Division, Near P.D. Office, Akhnora, Pin- 181201 (Test Address only)

Test report

Sample ID: U1700970515148007

User Information

Name: RMG INTERNATIONAL SCHOOL

Mobile: 9419100339

Email: rmginternationalschool@gmail.com

Pin Code:

Full Address: Village- JANDIAL, Gram Panchayat- Jandyal upper, Block- Mathwar, District- Jammu, State- Jammu & Kashmir

Sample description

Source of Sample: Schools

Village: JANDIAL

Gram Panchayat: jandyal upper

Block: Mathwar

District: Jammu

State: Jammu & Kashmir

Address:

Remarks:

Latitude: 32.889990

Longitude: 74.780445

Date & time of sample collection

09.09.2023 | 12:10:00 PM

Date & time of sample received in lab

09.09.2023 | 01:30:00 PM

Date & time of sample analysed

09.09.2023 | 02:40:00 PM

Date & time of report generation

11.09.2023 | 10:45:53 AM

Test results

Sr. No.	Parameters tested	Unit of measurement	Requirement (acceptable limit) as per BIS 10500	Permissible limit (in absence of alternate source) as per BIS 10500	Test result value	Remarks
1	Calcium (as Ca)	mg/l	75	200	100.000	SAFE
2	Chloride (as Cl)	mg/l	250	1000	250.000	SAFE
3	E. coli	CFU/100 ml	Shall not be detectable in any 100 ml sample	No Relaxation	0.000	SAFE
4	Fluoride (as F)	mg/l	1	1.5	0.300	SAFE
5	Free residual Chlorine	mg/l	0.2	1	0.000	SAFE

M. R. Bhatia
Principal
RMG International School
Jandial (Zone Bhalwal), Jammu

6	Iron (As Fe)	mg/l	1	No Relaxation	0.000	SAFE
7	Nitrate (as NO ₃)	mg/l	45	No Relaxation	3.000	SAFE
8	pH	NA	6.5-8.5	No Relaxation	7.000	SAFE
9	sulphate (as SO ₄)	mg/l	200	400	230.000	SAFE
10	TDS	mg/l	500	2000	261.000	SAFE
11	Total Alkalinity (as Calcium Carbonate)	mg/l	200	600	250.000	SAFE
12	Total Hardness (As CaCO ₃)	mg/l	200	600	290.000	SAFE
13	Turbidity	NTU	1	5	0.140	SAFE

Note:

- 1) *Indicates parameters that are NABL accredited.
- 2) This test results related to the sample tested above
- 3) The report shall not to be reproduced in full without approval of authority
- 4) This is the end of the report

Authorised signatory

Amit Sharma (Test Lab Incharge)

Jal Jeevan Mission aims at potable tap water supply to every home

Let's join hands to ensure drinking water is potable. It helps in preventing water borne diseases and improve public health.

Designed & Developed by NIC. Copyright ©copy NJIM 2023

M. V. S. Rathore
Principal
RMG International School
Jandial (Zone Bhalwal), Jammu